


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 103Dated: 23/01/2026It is certified that an inspection team headed by MR. R.G. GADHANE A.E.(Name of Officers with designation) from P.H.E Sub. div. Seoni (MP) 480661PHED inspected the Arunanchal Public School, Gram Setewani, Kurai, Dist.- Seoni, MP on 23.01.2026 andon the basis of Water Test Report (Attached) bearing no. 488/AE/lab/PHE/Seoni dated20.01.2026 of P.H.E/lab/ Sub div/ Seoni

(PHED Lab) certified that the Arunanchal Public School, Gram Setewani, Kurai, Dist.- Seoni, MP has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with seal


 23.01.2026

Name

R.G. GADHANE
 Assistant Engineer
 Public Health Engg.
 Sub. Division Seoni

Designation

Name & address of the office/Department: - _____

To,

Arunanchal Public School,
 Gram Setewani, Kurai, Dist.- Seoni, MP
 (Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

अरुनचल
 अध्यापक
 तन्मय शिक्षा समिति
 सिवनी (म.प्र.)


PRINCIPAL
 ARUNANCHAL PUBLIC SCHOOL
 SETEWANI (KURAI)
 DISTT. SEONI (M.P.)

OFFICE OF ASSISTANT ENGINEER, PUBLIC HEALTH ENGG. SUB-DIVISION SEONI (M.P.)

DISTRICT WATER TESTING LABORATORY, SEONI (M.P.)

Address :- NEAR CIRCUIT HOUSE POLICE LINE SEONI (M.P.)

WATER TESTING REPORT

Status of Sample	Drinking water and other	Unique Identification No.	—
Sender's name	प्राचार्य	Sender's letter no. & date	00 19/01/2026
Sender's address	अरूणाचल पब्लिक स्कूल ग्राम सेटेवानी कुरई जिला जिला सिवनी (म.प्र.)	Year Ref. letter no. & date	324 19/01/2026
		Start Date Of Analysis	19/01/2026 To 20/01/2026
Quantity of Sample	—	DWTL receipt No.	—
Sample Collected by lab (Yes/No)	No	End Date Of Analysis	20/01/2026
FORM M.P.T.C.6 [See subsideir Rule 43(1)]			RECEIPT
Book No.	40847	MR (Serial No.) & Date	

Sample details:

S. No.	Block	Panchayat	Village	Habitation	Location
1	कुरई	सेटेवानी	सेटेवानी	सेटेवानी	अरूणाचल पब्लिक स्कूल


Physical & Chemical Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS. (BIS 10500:2012)


S. No.	Colour Hazen unit (5-15)	Odour (Unobjectionable)	Taste (Agreeable)	Turbidity (1-5) (NTU)	pH (6.50 - 8.50) (at pH scale)	TDS (500-2000) (mg/l)	Alkalinity (200-600) (mg/l)	Chloride (250 -1000)(mg/l)	Fluoride (1.00 -1.50) (mg/l)	Nitrate (45 -45) (mg/l)	Sulphate (200-400) mg/l	Calcium as Ca++ (75-200) (mg/l)	Magnesium asMg (30-100) (mg/l)	Total Hardness (200-600) (mg/l)	Iron (0.30 -1.00) (mg/l)	Arsenic (0.01-0.01) (mg/l)	Total Coliform / E coli (0/100 ml)	Manganese (0.1-0.3) (mg/l)
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
1	0	Agreeable		1.8	7.39	243.00	60.00	70.00	0.20	0.00	16.70	24.00	16.70	200.00	0.10	-	0/100 ml	0.00


Note - 1. Samples are not collected by us. 2. Not to be produced at court of law. 3. We do not take any responsibility for deviation in test result due to wrong collection of sample


Technical Manager
District Water Testing lab
P.H.E.Sub.Divl. Seoni


Quality Manager
District Water Testing lab
P.H.E.Sub.Divl. Seoni


Assistant Engineer,
P.H.E. Sub Division
Seoni (M.P.)
सोन, स्वा. सार्वजनिक स्वामित्व सिवनी (म.प्र.)


अध्यक्ष
तन्मय शिक्षा समिति
सिवनी (म.प्र.)


PRINCIPAL
ARUNANCHAL PUBLIC SCHOOL
SETEWANI (KURAI)